

LOSS FACTORS EFFECTIVE FROM 1 APRIL 2026

To facilitate the allocation and reconciliation of Grid Exit Point electricity volumes, the following loss factors should be used for electricity traded across the Network Waitaki network.

Code	Description	Anytime Loss Factor
WLW	Installations metered at low voltage	1.055
W11	Installations metered at 11kV	1.023
W110	Installations metered at 110kV	1.000
WLV0291	Installations metered at low voltage, site-specific configuration	1.034